KERALA CRICKET ASSOCIATION

PART A - Renovation /Replacement of existing MH fittings to LED Flood lights and allied Electrical works for upcoming ICC Women's World Cup at Sports Hub Green Field International Stadium Thiruvananthapuram - Supply of LED Flood Light

TENDER SCHEDULE

Ite m No	Quantity	Unit	Details of work	Rate in figures	Unit	Rate in words	Amount
1	208	nos	Supply of professional sports lighting LED flood light luminaire with greater than 1,78,000 Lumens Light output with power consumption not more than 1600w(+/-10w), CRI >90,TLCI >90,Ripple value should be less than 5%. Greater than 100K Burning hour's life as per L 70 value. The weight of Luminaire shall be not more than 18 Kg and driver of 7 Kg. The Luminaire shall be designed with inbuilt cooling fan of MIN 7 no's IP68 Protection for excellent terminal management for LED Compartment.Joining of 2 or more fittings together to achieve wattage is not acceptable. Integrated Peanut Lens shall be mounted on each LED by injection moulding process on PC cover to reduce vaccum space inside LED module and the fittings shall have minimum IP66 with IK08 protection. Driver shall be future proof DMX -RDM enabled suitable for invidual control of Philips make only. (The Bidder shall submit an authorization letter from Philips Brand / Signify Innovations India Limited, specifically mentioning the tender name, duly signed by the Zonal Head or an official of higher authority)		/nos		
			TOTAL		Rs.		
			Add GST @ 18 %		Rs.		
			Grand Total		Rs.		
			Rounded to		Rs.		

Rupees in words :

Signature of Contractor:

Name and adress

Place : Date :